

DONALD TUCKER  
CHAIRMAN  
RAYMOND LUCHKO  
VICE CHAIRMAN

ROBERT M. BURKE, JR.  
THOMAS J. CIFELLI  
JAMES KRONE  
FRANK ORECHIO  
COMMISSIONERS



Passaic Valley  
Sewerage Commissioners

600 WILSON AVENUE  
NEWARK, N.J. 07105  
(201) 344-1800  
Fax: (201) 344-2951

60027 S.S.3  
JDR  
CARMINE T. PERRAPATO  
EXECUTIVE DIRECTOR

ROBERT J. DAVENPORT  
DEPUTY EXECUTIVE DIRECTOR

GABRIEL M. AMBROSIO  
CHIEF COUNSEL

May 3, 1991

Mrs. Lisa Murtha Bromberg  
Porzio, Bromberg & Newman  
163 Madison Avenue  
Morristown, New Jersey 07962-1997

**RE: DISCHARGE OF TREATED GROUNDWATER HEXCEL CORPORATION**

Dear Mrs. Bromberg:

This letter is in reference to your letter of April 8, 1991. Please be advised that Passaic Valley Sewerage Commissioners approves the temporary discharge of test water to the sanitary sewer for the period of two weeks. In addition, your request to discharge this pretreated groundwater for 6 months while you investigate alternative disposal methods is also approved (7200 gallons/day maximum). Hexcel Corporation must adhere to the following in reference to this discharge:

1. Discharge not to exceed more than 5 gallons/minute (maximum 7200 gallons/day;
2. Adjust flow rate to insure that sewer line is not surcharged;
3. Monitoring Frequency and Parameters to be analyzed shall be in accordance with your 04/08/91 letter;
4. Treatment system to be installed as per Heritage Company letter of 02/04/91;
5. Volume to be metered;
6. Comply with PVSC Rules and Regulations;
7. Mr-2 Form to be submitted to PVSC quarterly (monthly after 7/1/91);

It is important to note that PVSC's position in reference to the permanent discharge of this groundwater is unchanged. Also, please be certain that the alternative evaluation includes the isolation of this discharge from that of Fine Organics. PVSC will not consider any extension of this approval, if it became necessary, unless this was accomplished.

PVSC requests that a monthly status report outlining your milestones and progress be submitted. Mario Graglia, Supervisor of Monitoring & Surveillance (201) 817-5724 must be notified 7-10 days prior to commencing any discharge of this pretreated groundwater.

MAY - 6 RECD

SDMS Document



88474

RE: DISCHARGED TREATED GROUNDWATER HEXCEL CORPORATION

May 3, 1991

Page 2

If you require any additional information in reference to this matter, please contact Carmen Della Pia, Operations Coordinator at (201) 817-5717. Finally, PVSC requests that a properly authorized representative of Henkel Corporation reply to this letter accepting the conditions listed above prior to commencing the 6 month discharge.

Very truly yours,

PASSAIC VALLEY SEWERAGE COMMISSIONERS



Frank P. D'Ascensio  
Manager of Industrial & Pollution Control

FPD/mc

cc: Carmine T. Perrapato, Executive Director  
Robert Davenport, Deputy Executive Director  
Mario Graglia  
Carmen Della Pia  
J. Ritchey  
J. Higdon

884740002